


GLAZED FLAT PLATE SOLAR COLLECTORS Models EC and EP SPECIFICATION SHEET

THE STANDARD IN SOLAR WATER HEATING TECHNOLOGY



PROTECTING OUR ENVIRONMENT—SINCE 1978

SUNEARTHINE. EMPIRE SERIES SPECIFICATIONS

SunEar Model N	Width Incheo	Lengi Inches	Dept	Sop. Sop.	- / 2 -		Fluid Cap		Pressure at Design Rate Soure	Max Fi	Deerating	Sta He Sta He Width, In	Diameter I	Header, to Center, I	
EC/EP21	40	76	3 1/4	21.12	18.70	70	0.72	0.54	0.003	12	160	43 3/8	1	71.25	
EC/EP24	36 1/8	98 1/4	3 1/4	24.61	21.88	80	0.78	0.62	0.005	12	160	39 3/4	1	93 5/8	
EC/EP32	48 1/8	98 1/4	3 1/4	32.79	29.81	106	1.00	0.83	0.006	12	160	51 3/8	1	93 5/8	
EC/EP-32-1.5	48 1/8	98 1/4	3 1/4	32.79	29.81	115	1.41	0.83	0.004	25	160	51 3/8	1 1/2	93 5/8	
EC/EP40	48 1/8	122 1/4	3 1/4	40.81	37.33	141	1.20	1.04	0.009	12	160	51 3/8	1	115 5/8	
EC/EP40-1.5	48 1/8	122 1/4	3 1/4	40.81	37.33	150	1.61	1.04	0.006	25	160	51 3/8	1 1/2	115 5/8	

MODEL EC

THERMAL PERFORMANCE RATINGS*

MODEL EP

CLOUDY

DAY

1000

645

570

410

70

BTU/ft²·Dav

	BTU/ft ^{2.} Day					
Category (Ti-Ta) Ti = inlet fluid temp Ta = ambient air temp	CLEAR DAY 2000 BTU/ft ^{2.} Day	MILDLY CLOUDY DAY 1500 BTU/ft ^{2.} Day	CLOUDY DAY 1000 BTU/ft ^{2.} Day		Category (Ti-Ta) Ti = inlet fluid temp Ta = ambient air temp	
A(-9°F)	1,360	1,020	690		A(-9°F)	
B(9°F)	1,250	910	580		B(9°F)	
C(36°F)	1,070	745	420		C(36°F)	
D(90°F)	700	400	120		D(90°F)	
E(144°F)	330	95	-		E(144°F)	

A-Pool Heating (Warm Climate) B-Pool Heating C-Water Heating (Warm Climate) D-Water Heating (Cool Climate) E-Air Conditioning/Industrial Process Heat. **Thermal performance is obtained by multiplying the collector output for the appropriate application and insolation level by the total gross collector area.** *Collector ratings are derived from the Solar Rating & Certification Corp (SRCC) Document RM-1 and Standard OG-100.

ENGINEERING SPECIFICATIONS

The following shall be the specifications for the solar collectors. Collectors shall be SunEarth Empire model ______, and shall be of the glazed liquid flat plate type. Collectors shall be tested in conformance with ASHRAE 93-2003 and Solar Rating and Certification Corporation (SRCC) Standard 100-05, and have their thermal performance rated according to SRCC Document RM-1. The collectors shall be certified by the SRCC and the Florida Solar Energy Center (FSEC), and listed by the International Association of Plumbing and Mechanical Officials (IAPMO).

GENERAL

The dimensions of the collector shall be ______ inches in length, ______ inches in width and 3 1/4 inches in depth. The collector casing shall be an anodized aluminum extrusion (alloy 6063 T5), minimum thickness .060 inch, with an architectural dark bronze finish. The casing shall have notched framewalls for ease of plate removal and reinstallation. Sheet metal screwed fasteners shall be stainless steel (18-8 #10). The backsheet shall be painted textured aluminum not less than .014 inch thickness. A 1 inch vent plug shall be installed in each of the four corners of the backsheet to minimize condensation. An integral mounting channel shall allow the solar collector to be mounted without penetration of the extruded aluminum casing.

GLAZING

The collector glazing shall be one sheet of low iron tempered glass, with a minimum of 1/8 inch thickness (5/32 inch on EC/EP 40), and a minimum transmissivity of 91 percent (89 on EC/EP 40). The glazing shall be thermally isolated from the casing by a continuous EPDM gasket. There shall be a continuous secondary silicone seal between the glass and casing capstrip to minimize moisture from entering the casing.

INSULATION

The insulation shall be foil-faced polyisocyanurate foam sheathing board of a minimum 1 inch thickness, siliconed in place to the aluminum backsheet, covered by low-binder fiberglass of a minimum 1 inch thickness, providing

(Performance specifications subject to testing error of +/- 3%)

IP Units BTU/ft^{2.}Day

MILDLY

CLOUDY DAY

BTU/ft^{2.}Day

965

890

720

315

CLEAR

DAY

2000

BTU/ft².Day

1,290

1,210

1,035

600

150

thermal isolation of the foam from the absorber plate. Total thermal resistance shall be a minimum of R-12. The sides and ends of the collector shall be insulated with a minimum of 1 inch foil-faced polyisocyanurate foam sheathing board.

ABSORBER PLATE AND PIPING

The absorber shall consist of a roll-formed copper plate of no less than .008 inch thickness. Risers shall be a minimum of 1/2 inch O.D. Type M copper tubing on no more than 4 1/2 inch centers continuously soldered to the plate utilizing a non-corrosive solder paste with a melting point of 460° F. The risers shall be brazed to 1 1/8" O.D. Type M copper manifolds (1 5/8" O.D. on models EC/EP-32-1.5 and EC/EP-40-1.5) utilizing a copper phosphorous brazing alloy with no less than 15 percent silver content, and conforming to the American Welding Society's BCuP-5 classification. EPDM grommets shall isolate the manifold from the aluminum casing. The absorber plate shall be designed for 160 psig maximum operating pressure.

ABSORBER COATING AND PERFORMANCE CURVE

A) Black Chrome (EC Series): The absorber coating shall be black chrome on nickel with a minimum absorptivity of 95 percent and a maximum emissivity of 12 percent. The instantaneous efficiency of the collector shall be a minimum Y-intercept of 0.735 and a slope of no less than -0.730 BTU/ft²·hr.^oF.

B) Moderately Selective Black Paint (EP Series): The absorber coating shall be a moderately-selective black paint with a minimum absorptivity of 94 percent and a maximum emissivity of 56 percent. The instantaneous efficiency of the collector shall have a minimum Y-intercept of 0.726 and a slope of no less than -0.910 BTU/ft²·hr^oF.

Note: Please refer to the SRCC website at www.solar-rating.org for the actual y-intercept and slope for each collector.

Due to SunEarth's policy of continuous product improvement, specifications are subject to change without notice.

Due to Sullauti s policy of commoous produ	chimprovement, specifications are subject to change without holice.
MANUFACTURED BY:	AVAILABLE FROM:
SunEarth SunEarth 8425 Almeria Ave. • Fontana, CA 92335 (909) 434-3100 • Fax (909) 434-3101 www.sunearthinc.com	RECYCLED PAPER-SOY BASED INK